

# South Coast Air Quality Management District

## Facility Equipment List Report



Facility: 138823 HUDD DIST SERVICES INC  
Last Inspection: 04/27/2005  
SIC:  
Inspector: LB02 LALO A. BAKHOUM  
Inspection Date: 04/27/2005  
Location Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC  
Mailing Address: 5011 FIRESTONE PL, SOUTH GATE 90280-3533 Sector:LC  
Instruction:

MR:  
TS: TS-11 Industrial: Sector-based In  
Facility Status: Active  
Assignment No. 882772  
Disposition: Operating in Compliance at time of inspection

Contact: LEWIS FAKKAS Jr. (323) 5682603  
Quarter: 1000 - inspect in 1st quarter, every year  
On Hold: N  
Suspended: N  
Facility Team: J

RECLAIM: N	TITLE V: N	SIP:	AIR:
Application No.	Permit No.	Permit Issue Date	Permit Status
Equipment Category	BCAT/CCAT Description	Application Date	Application Status
426851	043901	BCAT	I C E (50-500 HP) EM ELEC GEN-DIESEL
			03/09/2004 ASSIGNED TO ENGINEER - CLASS III

Report: On April 27, 05, I arrived at the above-mentioned Hudd location, pursuant to compliant inspection. Hudd distribution services, Inc., is one of the largest warehouse/storage, distribution services for Wall- Mart, Sears and other department stores. I met with Mr. Lewis Farkas, facility manager, and Mr. David Fitzsimmons, maintenance supervisor. Facility is equipped with one ICE; Perkins, OLYPIAN D100P2, Engine Family "XPKXL05-9YH1", Serial number YB50604U708557D, Diesel-fired, 151 hp, that powered an emergency generator. The engine was running for approx. 5 minutes /week for testing and service by David. The Engine P/O not issued yet for, because of emissions records that needed from the Mfg.

Inspector:  Date: 5/5/05 Reviewed By:  Date: 6-7-05